

Central Iowa Code Consortium - Code Proposal Form

Note - Each code section proposal must be submitted on a separate form

Name: *

Brian Bishop

Organization

City of Des Moines

Email Address *

bdbishop@dmgov.org

Confirm Email Address *

bdbishop@dmgov.org

Phone *

515-283-4958

Code Book *

Resource for code content - <https://codes.iccsafe.org/public/collections/I-Codes>

IBC - International Building Code



Code Section *

See example below. DO NOT INCLUDE ANY LEADING ALPHA CHARACTERS! Resource for code language - <https://codes.iccsafe.org/public/collections/I-Codes>

1008.3.3 Rooms and Spaces

Is this an Appendix Chapter? *

Yes

No

If yes, which appendix?

Allowing Alpha Characters

Code Section Example

~~X~~101.1 Title.

These provisions shall be known as the *Residential Code for One- and Two-family Dwellings* of [NAME OF JURISDICTION], and shall be cited as such and will be referred to herein as "this code."

~~X~~101.2 Scope.

The provisions of the *International Residential Code for One- and Two-family Dwellings* shall apply to the construction, *alteration*, movement, enlargement, replacement, repair, *equipment*, use and occupancy, location, removal and demolition of detached one- and two-family dwellings and *townhouses* not more than three stories above *grade plane* in height with a separate means of egress and their *accessory structures* not more than three stories above *grade plane* in height.

Type of proposal *

Amend - Edit current section - change words | Delete - Remove section | Insert - Add text to existing section

Amend

Delete

Insert

Amend

Existing Text *

Full text as it is printed in the Code. Book Resource for code language -

<https://codes.iccsafe.org/public/collections/I-Codes>

Amend CICC amendment for this section to revert to 2018 IBC language. Replace item #5 with the following language:

5. Restrooms containing more than one water closet/ urinal or that are accessible.

Proposed Text *

1008.3.3 Rooms and spaces. In the event of power supply failure, an emergency electrical system shall automatically illuminate all of the following areas:

1. Electrical equipment rooms.
 2. Fire command centers.
 3. Fire pump rooms.
 4. Generator rooms.
 5. Public restrooms with an area greater than 300 square feet
-

Delete

This text is being proposed to be struck from the adopted code.

Existing Text to be struck *

Resource for code language - <https://codes.iccsafe.org/public/collections/I-Codes>

Insert

This text is being proposed to be added to the 2018 International Code for adoption by local municipalities.

Provide your new proposed code to be added to the existing code as cited above. *

Justification for Proposal

Provide reason to support your proposal based on the safety impact, enforceability, cost effectiveness, or unique location conditions

Justification *

The original intent for the code change to require emergency lighting in large restrooms was to get people to an exit since it might be confusing with no natural lighting, many doors and twist and turns. Requiring emergency lighting in most all restrooms seems excessive.

This content is neither created nor endorsed by Google.

Google Forms