

Central Iowa Code Consortium - Code Proposal Form

Note - Each code section proposal must be submitted on a separate form

Name: *

Brian Hamner

Organization

City of Des Moines

Email Address *

bjhamner@dmgov.org

Confirm Email Address *

bjhamner@dmgov.org

Phone *

515-283-4963

Code Book *

Resource for code content - <https://codes.iccsafe.org/public/collections/I-Codes>

UPC- Uniform Plumbing Code



Code Section *

See example below. DO NOT INCLUDE ANY LEADING ALPHA CHARACTERS! Resource for code language - <https://codes.iccsafe.org/public/collections/I-Codes>

813.1

Is this an Appendix Chapter? *

Yes

No

If yes, which appendix?

Allowing Alpha Characters

Code Section Example

~~101.1~~ Title.

These provisions shall be known as the *Residential Code for One- and Two-family Dwellings* of **[NAME OF JURISDICTION]**, and shall be cited as such and will be referred to herein as “this code.”

~~101.2~~ Scope.

The provisions of the *International Residential Code for One- and Two-family Dwellings* shall apply to the construction, *alteration*, movement, enlargement, replacement, repair, *equipment*, use and occupancy, location, removal and demolition of detached one- and two-family dwellings and *townhouses* not more than three stories above *grade plane* in height with a separate means of egress and their *accessory structures* not more than three stories above *grade plane* in height.

Type of proposal *

Amend - Edit current section - change words | Delete - Remove section | Insert - Add text to existing section

Amend

Delete

Insert

Amend

Existing Text *

Full text as it is printed in the Code. Book Resource for code language - <https://codes.iccsafe.org/public/collections/I-Codes>

813.1 General. Pipes carrying wastewater from swimming or wading pools, including pool drainage and backwash from filters, shall be installed as an indirect waste.

Where a pump is used to discharge waste pool water to the drainage system, the pump discharge shall be installed as an indirect waste.

Proposed Text *

813.1 General. In other than single family dwellings and duplexes, pipes carrying wastewater from swimming pools, wading pools, or hot tubs, including pool drainage, backwash from filters, water from scum gutter drains or floor drains which serve walks around pools, shall be installed as an indirect waste by an air gap. Where the recirculation pump is used to discharge waste pool water to the drainage system, the pump discharge shall be installed as an indirect waste, with an air gap, to the sanitary sewer

Delete

This text is being proposed to be struck from the adopted code.

Existing Text to be struck *

Resource for code language - <https://codes.iccsafe.org/public/collections/I-Codes>

Insert

This text is being proposed to be added to the 2018 International Code for adoption by local municipalities.

Provide your new proposed code to be added to the existing code as cited above. *

Justification for Proposal

Provide reason to support your proposal based on the safety impact, enforceability, cost effectiveness, or unique location conditions

Justification *

Added additional sources of types of pools, hot tubs and other drainage to the section. It removes Single family and Duplexes from having to comply.

This content is neither created nor endorsed by Google.

Google Forms