

# Central Iowa Code Consortium - Code Proposal Form

Note - Each code section proposal must be submitted on a separate form

Name: \*

Brian Hamner

---

Organization

City of Des Moines

---

Email Address \*

bjhamner@dmgov.org

---

Confirm Email Address \*

bjhamner@dmgov.org

---

Phone \*

515-283-4963

---

Code Book \*

Resource for code content - <https://codes.iccsafe.org/public/collections/I-Codes>

UPC- Uniform Plumbing Code



## Code Section \*

See example below. DO NOT INCLUDE ANY LEADING ALPHA CHARACTERS! Resource for code language - <https://codes.iccsafe.org/public/collections/I-Codes>

715.1

---

## Is this an Appendix Chapter? \*

Yes

No

## If yes, which appendix?

Allowing Alpha Characters

---

## Code Section Example

### ~~X~~101.1 Title.

These provisions shall be known as the *Residential Code for One- and Two-family Dwellings* of [NAME OF JURISDICTION], and shall be cited as such and will be referred to herein as "this code."

### ~~X~~101.2 Scope.

The provisions of the *International Residential Code for One- and Two-family Dwellings* shall apply to the construction, *alteration*, movement, enlargement, replacement, repair, *equipment*, use and occupancy, location, removal and demolition of detached one- and two-family dwellings and *townhouses* not more than three stories above *grade plane* in height with a separate means of egress and their *accessory structures* not more than three stories above *grade plane* in height.

## Type of proposal \*

Amend - Edit current section - change words | Delete - Remove section | Insert - Add text to existing section

Amend

Delete

Insert

## Amend

### Existing Text \*

Full text as it is printed in the Code. Book Resource for code language -

<https://codes.iccsafe.org/public/collections/I-Codes>

---

### Proposed Text \*

---

## Delete

This text is being proposed to be struck from the adopted code.

### Existing Text to be struck \*

Resource for code language - <https://codes.iccsafe.org/public/collections/I-Codes>

---

## Insert

This text is being proposed to be added to the 2018 International Code for adoption by local municipalities.

Provide your new proposed code to be added to the existing code as cited above. \*

At the end the section add, " Compromised piping would consist of significant cracks, out of alignment piping, missing pieces from piping, and or fittings. If any portion of a bituminous fiber ("Orangeburg") building sewer fails, the Orangeburg sewer shall be replaced in its entirety from the building to the public sanitary sewer with new sewer that fully complies with this Code.

---

## Justification for Proposal

Provide reason to support your proposal based on the safety impact, enforceability, cost effectiveness, or unique location conditions

### Justification \*

Clarifies what compromised piping is, and requires that Orangeburg sewers are replaced and not repaired. There are already jurisdictions in the area that require Orangeburg is replaced and not repaired.

---

This content is neither created nor endorsed by Google.

Google Forms