

# Central Iowa Code Consortium - Code Proposal Form

Note - Each code section proposal must be submitted on a separate form

Name: \*

Brian Hamner

Organization

City of Des Moines

Email Address \*

bjhamner@dmgov.org

Confirm Email Address \*

bjhamner@dmgov.org

Phone \*

515-283-4963

Code Book \*

Resource for code content - <https://codes.iccsafe.org/public/collections/I-Codes>

UPC- Uniform Plumbing Code



## Code Section \*

See example below. DO NOT INCLUDE ANY LEADING ALPHA CHARACTERS! Resource for code language - <https://codes.iccsafe.org/public/collections/I-Codes>

604.0

---

## Is this an Appendix Chapter? \*

Yes

No

## If yes, which appendix?

Allowing Alpha Characters

---

## Code Section Example

### ~~101.1~~ Title.

These provisions shall be known as the *Residential Code for One- and Two-family Dwellings* of [NAME OF JURISDICTION], and shall be cited as such and will be referred to herein as "this code."

### ~~101.2~~ Scope.

The provisions of the *International Residential Code for One- and Two-family Dwellings* shall apply to the construction, *alteration*, movement, enlargement, replacement, repair, *equipment*, use and occupancy, location, removal and demolition of detached one- and two-family dwellings and *townhouses* not more than three stories above *grade plane* in height with a separate means of egress and their *accessory structures* not more than three stories above *grade plane* in height.

## Type of proposal \*

Amend - Edit current section - change words | Delete - Remove section | Insert - Add text to existing section

Amend

Delete

Insert

## Amend

### Existing Text \*

Full text as it is printed in the Code. Book Resource for code language -

<https://codes.iccsafe.org/public/collections/I-Codes>

---

### Proposed Text \*

---

## Delete

This text is being proposed to be struck from the adopted code.

### Existing Text to be struck \*

Resource for code language - <https://codes.iccsafe.org/public/collections/I-Codes>

---

## Insert

This text is being proposed to be added to the 2018 International Code for adoption by local municipalities.

Provide your new proposed code to be added to the existing code as cited above. \*

In areas served by Des Moines Water Works, water service materials shall comply with Des Moines Water Works regulations. PVC piping of four inches or larger may be used for service lines provided that it conforms to AWWA standard C 900 DR 14 and the following:

- (1) Tracer wire shall be installed with all water service lines except when the water service line is type K copper or red brass. The tracer wire shall be installed according to Des Moines Water Works' specifications
  - (2) PVC shall not be used within five feet of a building.
- 

---

## Justification for Proposal

Provide reason to support your proposal based on the safety impact, enforceability, cost effectiveness, or unique location conditions

### Justification \*

This give direction for contractors to follow DMWW rules and regulations for the installations of water services that are installing in areas serviced by DMWW. Areas that are not serviced by DMWW may have different rules and regulations.

---

This content is neither created nor endorsed by Google.

Google Forms