

Central Iowa Code Consortium - Code Proposal Form

Note - Each code section proposal must be submitted on a separate form

Name: *

Mike Minnick

Organization

Email Address *

mrminnick@dmgov.org

Confirm Email Address *

mrminnick@dmgov.org

Phone *

515-237-1462

Code Book *

Resource for code content - <https://codes.iccsafe.org/public/collections/I-Codes>

IMC - International Mechanical Code



Code Section *

See example below. DO NOT INCLUDE ANY LEADING ALPHA CHARACTERS! Resource for code language - <https://codes.iccsafe.org/public/collections/I-Codes>

603.12

Is this an Appendix Chapter? *

Yes

No

If yes, which appendix?

Allowing Alpha Characters

Code Section Example

~~X~~101.1 Title.

These provisions shall be known as the *Residential Code for One- and Two-family Dwellings* of **[NAME OF JURISDICTION]**, and shall be cited as such and will be referred to herein as “this code.”

~~X~~101.2 Scope.

The provisions of the *International Residential Code for One- and Two-family Dwellings* shall apply to the construction, *alteration*, movement, enlargement, replacement, repair, *equipment*, use and occupancy, location, removal and demolition of detached one- and two-family dwellings and *townhouses* not more than three stories above *grade plane* in height with a separate means of egress and their *accessory structures* not more than three stories above *grade plane* in height.

Type of proposal *

Amend - Edit current section - change words | Delete - Remove section | Insert - Add text to existing section

Amend

Delete

Insert

Amend

Existing Text *

Full text as it is printed in the Code. Book Resource for code language - <https://codes.iccsafe.org/public/collections/I-Codes>

Proposed Text *

Delete

This text is being proposed to be struck from the adopted code.

Existing Text to be struck *

Resource for code language - <https://codes.iccsafe.org/public/collections/I-Codes>

Insert

This text is being proposed to be added to the 2018 International Code for adoption by local municipalities.

Provide your new proposed code to be added to the existing code as cited above. *

Bathroom, domestic kitchen and dryer exhaust vent ducted to an outside wall shall be insulated 10' back from an outside wall to help prevent condensation issues unless the duct is in an unconditioned space, then the entire duct shall be insulated.

Justification for Proposal

Provide reason to support your proposal based on the safety impact, enforceability, cost effectiveness, or unique location conditions

Justification *

To provide some clarification to code officials, contractors, design professionals, etc on when insulating of exhaust duct shall be required. Often the terminations with back draft dampers do not seal well enough to prevent the migration of cold air into the exhaust duct which can cause a drop in temperature of the exhaust duct and when the warm exhaust hits the colder duct condensation can occur.

This content is neither created nor endorsed by Google.

Google Forms