

Central Iowa Code Consortium - Code Proposal Form

Note - Each code section proposal must be submitted on a separate form

Untitled Title 

Name: *

Mike Minnick

Organization

Email Address *

mrminnick@dmgov.org

Confirm Email Address *

mrminnick@dmgov.org

Phone *

515-237-1462

Code Book *

Resource for code content - <https://codes.iccsafe.org/public/collections/I-Codes>

IRC - International Residential Codes



Code Section *

See example below. DO NOT INCLUDE ANY LEADING ALPHA CHARACTERS! Resource for code language - <https://codes.iccsafe.org/public/collections/I-Codes>

M1602.2

Is this an Appendix Chapter? *

Yes

No

If yes, which appendix?

Allowing Alpha Characters

Code Section Example

~~101.1~~ **Title.**

These provisions shall be known as the *Residential Code for One- and Two-family Dwellings* of **[NAME OF JURISDICTION]**, and shall be cited as such and will be referred to herein as “this code.”

~~101.2~~ **Scope.**

The provisions of the *International Residential Code for One- and Two-family Dwellings* shall apply to the construction, *alteration*, movement, enlargement, replacement, repair, *equipment*, use and occupancy, location, removal and demolition of detached one- and two-family dwellings and *townhouses* not more than three stories above *grade plane* in height with a separate means of egress and their *accessory structures* not more than three stories above *grade plane* in height.

Type of proposal *

Amend - Edit current section - change words | Delete - Remove section | Insert - Add text to existing section

- Modification
- Deletion
- Addition

Does this proposal impact other codes? *

- Yes
- No

If yes, indicate which code and code section?

.....

Does this proposal relate to a previously accepted CICC amendment? *

- Yes
- No

If yes, which previously accepted CICC amendment?

.....

Modification

Existing Text *

Full text as it is printed in the Code. Book Resource for code language -

<https://codes.iccsafe.org/public/collections/I-Codes>

Proposed Text *

Deletion

This text is being proposed to be struck from the adopted code.

Existing Text to be struck *

Resource for code language - <https://codes.iccsafe.org/public/collections/I-Codes>

Addition

This text is being proposed to be added to the 2018 International Code for adoption by local municipalities.

Provide your new proposed code to be added to the existing code as cited above. *

Supply air outlets shall be a minimum 4' horizontally and 5' vertically from return air openings.

Justification for Proposal

Provide reason to support your proposal based on the safety impact, enforceability, cost effectiveness, or unique location conditions

Justification *

Right now there are no minimum distances from supply and return air openings. I often see design professionals drawing supply air and return air openings directly next each other.

This content is neither created nor endorsed by Google.

Google Forms