Central Iowa Code Consortium - Code Proposal Form

Note - Each code section proposal must be submitted on a separate form

Untitled Title

Name: *

Ankeny Building Division - Jeff Harden

Organization

City of Ankeny

Email Address *

jharden@ankenyiowa.gov

Confirm Email Address *

jharden@ankenyiowa.gov

Phone *

515-963-3553

Code Book *

Resource for code content - https://codes.iccsafe.org/public/collections/I-Codes

IBC - International Building Code

Code Section *

See example below. DO NOT INCLUDE ANY LEADING ALPHA CHARACTERS! Resource for code language - https://codes.iccsafe.org/public/collections/I-Codes

1008.3.1

Is this an Appendix Chapter? *

- ○ Yes
- ◉ No

If yes, which appendix?

Allowing Alpha Characters

Code Section Example



101.1 Title.
These provisions shall be known as the *Residential Code for One- and Two-family Dwellings* of **[NAME OF JURISDICTION]**, and shall be cited as such and will be referred to herein as "this code."

101.2 Scope.
The provisions of the *International Residential Code for One- and Two-family Dwellings* shall apply to the construction, *alteration*, movement, enlargement, replacement, repair, *equipment*, use and occupancy, location, removal and demolition of detached one- and two-family dwellings and *townhouses* not more than three stories above *grade plane* in height with a separate means of egress and their *accessory structures* not more than three stories above *grade plane* in height.

Type of proposal *

Amend - Edit current section - change words | Delete - Remove section | Insert - Add text to existing section

- ○ Modification
- ◉ Deletion
- ○ Addition

Does this proposal impact other codes? *

- ○ Yes
- ◉ No

If yes, indicate which code and code section?

_____

Does this proposal relate to a previously accepted CICC amendment? *

- ◉ Yes
- ○ No

If yes, which previously accepted CICC amendment?

2015 CICC IBC 1008.3.1

Modification

Existing Text *

Full text as it is printed in the Code. Book Resource for code language - https://codes.iccsafe.org/public/collections/I-Codes

Proposed Text *

Deletion

This text is being proposed to be struck from the adopted code.

Existing Text to be struck *

Resource for code language - https://codes.iccsafe.org/public/collections/I-Codes

Section 1008.3.1. General
In the event of the power supply failure in rooms and spaces 400 square feet or greater an emergency electrical system shall automatically illuminate all of the following areas:

1. Aisles
2. Corridors
3. Exit access stairways and ramps

Addition

This text is being proposed to be added to the 2018 International Code for adoption by local municipalities.

Provide your new proposed code to be added to the existing code as cited above. *

Justification for Proposal

Provide reason to support your proposal based on the safety impact, enfforceability, cost effectiveness, or unique location conditions

Justification *

It is believed the intent is to require rooms that are 400 square feet in area to be required to have emergency lighting. The adopted provision does not require rooms that are 400 square feet or more to have emergency lighting. This amendment only requires emergency lighting for rooms and/or spaces that are enumerated in items 1 through 3 regardless of the rooms' size. The provision eliminated the code requirement to mandate emergency lighting in rooms or spaces that require two means of egress. This provision actually raises the level of hazard of what is provided for in the code.

This content is neither created nor endorsed by Google.

Google Forms