Central Iowa Code Consortium - Code Proposal Form

Note - Each code section proposal must be submitted on a separate form

Untitled Title

Name: *

David Kuhn

Organization

City of Urbandale

Email Address *

dkuhn@Urbandale.Org

Confirm Email Address *

dkuhn@Urbandale.Org

Phone *

(515) 331 - 6725

Code Book *

Resource for code content - https://codes.iccsafe.org/public/collections/I-Codes

IBC - International Building Code

Code Section *

See example below. DO NOT INCLUDE ANY LEADING ALPHA CHARACTERS! Resource for code language - https://codes.iccsafe.org/public/collections/I-Codes

1013.7

Is this an Appendix Chapter? *

- ○ Yes
- ◉ No

If yes, which appendix?

Allowing Alpha Characters

Code Section Example



101.1 Title.
These provisions shall be known as the *Residential Code for One- and Two-family Dwellings* of **[NAME OF JURISDICTION]**, and shall be cited as such and will be referred to herein as "this code."

101.2 Scope.
The provisions of the *International Residential Code for One- and Two-family Dwellings* shall apply to the construction, *alteration*, movement, enlargement, replacement, repair, *equipment*, use and occupancy, location, removal and demolition of detached one- and two-family dwellings and *townhouses* not more than three stories above *grade plane* in height with a separate means of egress and their *accessory structures* not more than three stories above *grade plane* in height.

Type of proposal *

Amend - Edit current section - change words | Delete - Remove section | Insert - Add text to existing section

- ○ Modification
- ○ Deletion
- ◉ Addition

Does this proposal impact other codes? *

- ◉ Yes
- ○ No

If yes, indicate which code and code section?

The same section should be added to the Fire Code so the books are coordinated. I assume the committee takes care of this, and an additional submission is therefore not required.

Does this proposal relate to a previously accepted CICC amendment? *

- ○ Yes
- ◉ No

If yes, which previously accepted CICC amendment?

Modification

Existing Text *

Full text as it is printed in the Code. Book Resource for code language - https://codes.iccsafe.org/public/collections/I-Codes

Proposed Text *

Deletion

This text is being proposed to be struck from the adopted code.

Existing Text to be struck *

Resource for code language - https://codes.iccsafe.org/public/collections/I-Codes

Addition

This text is being proposed to be added to the 2018 International Code for adoption by local municipalities.

Provide your new proposed code to be added to the existing code as cited above. *

1013.7 No Exit

1013.7.1 Any door, passage, or stairway that is neither an exit nor a way of exit access and that is located or arranged so that it is likely to be mistaken for an exit shall be identified by a sign that reads as follows: NO EXIT

1013.7.2 The NO EXIT sign shall have the word NO in letters 2 in. high, with a stroke width of 3/4 in., and the word EXIT in letters 1 in. high. with the word EXIT below the word NO.

Justification for Proposal

Provide reason to support your proposal based on the safety impact, enfforceability, cost effectiveness, or unique location conditions

Justification *

There are instances where a door may seem to be a logical means of egress, how ever it will not lead a person to safety. While it may seem obvious to code officials to simply follow the exit signs, it may not be as obvious to a person in an emergency situation. A similar provision has been a requirement in NFPA 101 for sometime. OSHA 1910 Subpart E also contains similar language.

This content is neither created nor endorsed by Google.

Google Forms