

CENTRAL IOWA CODE CONSORTIUM
IBC-IFC COMMITTEE
DMFD, 28th & Dean Ave.
May 31, 2018

MEETING MINUTES

1. CALL TO ORDER

P. Phelan called meeting to order at 8:00 a.m.

2. ROLL CALL

P. Phelan, S. Mullen, M. Whitsell, J. Junker, S. Oltrogge, D. Strait, J. Williams, K. Rash

3. AGENDA APPROVAL

Whitsell motion, 2nd by Mullen. Motion approved.

4. PUBLIC COMMENT

none

5. APPROVE MINUTES FROM THE PREVIOUS MEETING

none

6. AGENDA

Approved P. Phelan as Chair; M. Whitsell as Vice Chair and S. Mullen as Secretary

Reviewed 2015 revisions to IBC-IFC Chaps 7-10

Discussed need to be aware of correlation changes between 2015 and 2018 editions as some 2015 references have changed in the 2018 edition.

Discussed 903.4.2 requirement for 110 candela strobe activated by sprinkler and its power supply requirements.

Discussed revisiting 907.6.6 Monitoring requirements.

Discussed 910.2.1 may have additional occupancies added.

Discussed 1008.3.1 May need modification to add clarity to where 400 SF applies and revise syntax language.

Discussed 1008.3.3 with clarification if it applies to fire sprinkler riser rooms.

Discussed 1010.1.6.1 needing clarification on frost protection and minor syntax corrections

Discussed 1030.5 revising reference section location to 1030.4.3 in 2018 edition

7. OTHER BUSINESS

none

8. UPCOMING MEETING

Next meeting date is: Thursday, June 28 8 a.m. – 10 a.m., location pending

9. ADJOURNMENT

Meeting adjourned at 10:00 a.m.

//submitted by S. Mullen