

**NEC/IECC Committee**

**Agenda**

**Date: 2/13/19**

**Time: 10:00 a.m.**

**Location: 705 North Ave., Norwalk, IA 50211**

1. **Call to order**
2. **Roll Call (X-present, A-absent)**
  - Jeff Duehlmeyer**
  - Ron Frazee**
  - Ryan Mayer (Chairman)**
  - Corey DePenning (Secretary)**
  - Erin Wiggins**
  - Chad Layland**
  - Mike Webster (Vice Chairman)**
  - Luke Nelson (Exec Board Liaison)**

3. **Agenda Approval**
4. **Approve minutes from previous meeting**
5. **Public Comment**
6. **Executive Liaison Update**
7. **Agenda**

**Proposed review and take action on the following code change proposals:**

1. Proposed addition to 2017 NEC – Electrical Service Update Code

The proposed electrical service update code is an opportunity for jurisdictions to adopt code provisions that would require minimum safety measures be met/installed when electrical service updates are made.

<b>Member</b>	<b>Motioned</b>	<b>2nd</b>	<b>YEA</b>	<b>NAY</b>	<b>ABSTAIN</b>
Jeff Duehlmeyer					
Ron Frazee					
Ryan Mayer					
Corey DePenning					
Erin Wiggins					
Chad Layland					
Mike Webster					

2. Proposed addition to 2012 IECC- Documentation Proposal

The proposed document is a guide for jurisdictions to use for projects that are required to follow the 2012 IECC. Guidance is given as to what is required at permit stage and at final

inspection stage before a certificate of occupancy is granted. The purpose of this document is to help promote consistency amongst jurisdictions.

<b>Member</b>	<b>Motioned</b>	<b>2nd</b>	<b>YEA</b>	<b>NAY</b>	<b>ABSTAIN</b>
Jeff Duehlmeyer					
Ron Frazee					
Ryan Mayer					
Corey DePenning					
Erin Wiggins					
Chad Layland					
Mike Webster					

3. Proposed addition to NEC.

Add 215.13 Prohibited Locations

Add 215.13.1 Townhomes not to be supplied through another.

Feeders supplying a townhome shall not extend through any townhome unit other than the unit served. For the purposes of this provision, the term townhome shall mean a single-family dwelling unit constructed in a group of two or more attached units in which each unit extends from foundation to roof and with a yard or public way on not less than two sides.

<b>Member</b>	<b>Motioned</b>	<b>2nd</b>	<b>YEA</b>	<b>NAY</b>	<b>ABSTAIN</b>
Jeff Duehlmeyer					
Ron Frazee					
Ryan Mayer					
Corey DePenning					
Erin Wiggins					
Chad Layland					
Mike Webster					

4. Proposed modification to NEC 210.8(A)(5)

Add exception #2 to (A)(5)

A single receptacle supplying an in ground sump discharge shall not be required to have ground-fault circuit interrupter protection if a receptacle protected by a ground fault circuit interrupter is installed within 3 feet adjacent the sump within the same room/space. This ground fault circuit interrupter is in addition to receptacles required in other sections of the code.

<b>Member</b>	<b>Motioned</b>	<b>2nd</b>	<b>YEA</b>	<b>NAY</b>	<b>ABSTAIN</b>
Jeff Duehlmeyer					
Ron Frazee					

Ryan Mayer					
Corey DePenning					
Erin Wiggins					
Chad Layland					
Mike Webster					

5. Proposed addition to NEC 250.104(B)

Add the following language under 250.104(B)

250.104 (B) CSST- Bonding Required

Where alterations, repairs or additions requiring a permit occur, CSST shall be bonded in accordance with 310.2.1 through 310.2.5 of the International Fuel Gas Code, unless deemed technically infeasible by the code official.

Member	Motioned	2nd	YEA	NAY	ABSTAIN
Jeff Duehlmeyer					
Ron Frazee					
Ryan Mayer					
Corey DePenning					
Erin Wiggins					
Chad Layland					
Mike Webster					

6. Proposed addition to IECC C402.1.1.

Add C402.1.1.1 Seasonal Structures.

The following seasonal type structures are exempt from meeting the provisions of this code.

1. Food Service Buildings that serve patrons at amusement parks, water parks and outdoor sporting facilities. The buildings can only be occupied by employees, must not be able to allow patrons to be served within the facility and must have as its sole means of serving customers, an operable exterior serving window.

2. Restroom Facilities that serve amusement parks, water parks and outdoor sporting facilities.

These facilities are allowed to have heating and/or cooling equipment for the temporary comfort of patrons and employees during operating hours.

Member	Motioned	2nd	YEA	NAY	ABSTAIN
Jeff Duehlmeyer					
Ron Frazee					
Ryan Mayer					
Corey DePenning					
Erin Wiggins					
Chad Layland					
Mike Webster					

**8. Other Business**

**9. Adjournment**

**Next Meeting: TBD**