

2018 Recommended Fuel Gas Code with Amendments

A **resolution** of the **Central Iowa Code Consortium** recommending adoption of the 2015 edition of the *National Fuel Gas Code*, regulating and governing the installation of fuel gas piping systems, appliances, equipment, and related accessories as shown in 1.1.1.1(A) through 1.1.1.1(D).

(A)* Coverage of piping systems shall extend from the point of delivery to the appliance connections. For other than undiluted liquefied petroleum gas (LP-Gas) systems, the point of delivery shall be the outlet of the service meter assembly or the outlet of the service regulator or service shutoff valve where no meter is provided. For undiluted LP-Gas systems, the point of delivery shall be considered to be the outlet of the final pressure regulator, exclusive of line gas regulators where no meter is installed. Where a meter is installed, the point of delivery shall be the outlet of the meter.

(B) The maximum operating pressure shall be 125 psi (862 kPa).

Exception No. 1: Piping systems for gas-air mixtures within the flammable range are limited to a maximum pressure of 10 psi (69 kPa).

Exception No. 2: LP-Gas piping systems are limited to 20 psi (140 kPa), except as provided in 5.5.1(6).

(C) Requirements for piping systems shall include design, materials, components, fabrication, assembly, installation, testing, inspection, operation, and maintenance.

(D) Requirements for appliances, equipment, and related accessories shall include installation, combustion, and ventilation air and venting.

The **Executive Committee** of the **Central Iowa Code Consortium** does ordain as follows:

Section 1. That a certain document, being marked and designated as the *National Fuel Gas Code*, 2015 edition, as published by the National Fire Protection Association®, published by the National Fire Protection Association, 1 Batterymarch Park, Quincy, MA 02169-7471, be and is hereby adopted as the Fuel Gas Code of the participating communities of the **Central Iowa Code Consortium**, for regulating and governing the installation of fuel gas piping systems, appliances, equipment, and related accessories; and each and all of the regulations, provisions, penalties, conditions and terms of said Fuel Gas Code are hereby referred to, adopted, and made a part hereof, as if fully set out in this legislation, with the additions, insertions, deletions and changes, if any, prescribed in Section 2 of this resolution.

Section 2. The following sections are hereby revised:

Delete Code Section: NFPA 54: 5.6.3.4

Replace with the following language:

5.6.3.4 Corrugated Stainless Steel. Only CSST with an Arc Resistant Jacket or Covering System listed in accordance with ANSI LC-1 (Optional Section 5.16)/CSA 6.26-2016 shall be installed in accordance with the terms of its approval, the conditions of listing, the manufactures instructions and this code including electrical bonding requirements in Section 7.13.2. CSST shall not be used for through wall penetrations from the point of delivery of the gas supply to the inside of the structure. CSST shall not be installed in locations where subject to physical damage unless protected in an approved manner.

DRAFT