

CENTRAL IOWA CODE CONSORTIUM
 MEETING MINUTES
 JOINT FIRE AND BUILDING CODE COMMITTEE
 DMFD AMT
 Classroom
 2715 Dean Ave
 Des Moines, IA 50317
 April 4, 2019 8 AM – 12 PM

AGENDA

1. CALL TO ORDER

Chairman Phelan called meeting to order at 8:10 a.m.

2. ROLL CALL

MEMBER	Present	Absent
Junker, J.		x
Mullen, S.	x	
Oltrogee, S.	x	
Phelan, P.	x	
Strait, D.	x	
Whitsell, M.	x	
Williams J.	x	

3. PREVIOUS MEETING MINUTES APPROVAL

Motion for approval of all meeting minutes for March 7, March 27 and March 29 by Whitsell; 2nd by Oltrogee

MEMBER	Yea	Nay
Junker, J.		
Mullen, S.	x	
Oltrogee, S.	x	
Phelan, P.	x	
Strait, D.	x	
Whitsell, M.	x	
Williams J.	x	

4. AGENDA APPROVAL

Motion for approval by Whitsell; 2nd by Mullen

MEMBER	Yea	Nay
Junker, J.		
Mullen, S.	x	
Oltrogee, S.	x	
Phelan, P.	x	
Strait, D.	x	
Whitsell, M.	x	
Williams J.	x	

5. AGENDA

- a. Review Process and rules for reviewing proposals.
- b. Begin reviewing proposals.

Code Section	Type of proposal	Description
903.2.1	Deletion	Deletion of Allowance for NFPA 13R sprinkler systems
903.2	Deletion	Delete Previous CICC amendment
907.2	Deletion	Delete Previous CICC amendment/exception

Considered 903.2.1 proposal for deletion of allowance for NFPA 13R sprinkler systems with proposed text incorporating friendly amendment adding reference for I occupancies.

903.3.1.2 NFPA 13R sprinkler systems. *Automatic sprinkler systems* in Group R and I occupancies up to and including four stories in height in buildings not exceeding 60 feet (18 288 mm) in height above grade plane shall be installed throughout in accordance with NFPA 13, unless allowed to be sprinklered in accordance with NFPA 13D by the International Building Code.
 The number of stories of Group R occupancies constructed in accordance with Sections 510.2 and 510.4 of the *International Building Code* shall be measured from the horizontal assembly creating separate buildings.

Motion to approve as proposed and modified by Phelan; 2nd by Whitsell

MEMBER	Yea	Nay
Junker, J.		
Mullen, S.	x	
Oltrogee, S.	x	
Phelan, P.	x	
Strait, D.		x
Whitsell, M.	x	
Williams J.		x

Considered 903.2 proposal for deletion of previous CICC amendment

Motion to approve by Strait; 2nd by Williams

MEMBER	Yea	Nay
Junker, J.		
Mullen, S.		x
Oltrogee, S.		x
Phelan, P.		x
Strait, D.	x	
Whitsell, M.		x
Williams J.	x	

Considered 903.2 proposal for deletion of previous CICC amendment

Motion deny proposal by Phelan; 2nd by Whitsell

Discussion of denial centered on fact this proposal was duplicative of 903.2 proposal.

MEMBER	Yea	Nay
Junker, J.		
Mullen, S.	x	
Oltrogee, S.	x	
Phelan, P.	x	
Strait, D.		x
Whitsell, M.	x	
Williams J.		x

Considered 907.2 proposal for deletion of previous CICC amendment/exception

Motion to approve by Strait; 2nd by Williams

MEMBER	Yea	Nay
Junker, J.		
Mullen, S.		x
Oltrogee, S.		x
Phelan, P.		x
Strait, D.	x	
Whitsell, M.		x
Williams J.	x	

Considered 907.2 proposal for deletion of previous CICC amendment

Motion deny proposal by Phelan; 2nd by Mullen

Discussion of denial centered on fact this proposal was duplicative of 907.2 proposal.

MEMBER	Yea	Nay
Junker, J.		
Mullen, S.	x	
Oltrogee, S.	x	
Phelan, P.	x	
Strait, D.		x
Whitsell, M.	x	
Williams J.		x

6. OTHER BUSINESS

Phelan will prepare slide deck for presentation to the CICC Executive Committee of this committee's actions on proposals.

7. REMINDER OF UPCOMING MEETING DATES

Tentative date of April 25 at 8 a.m. is set for review of slidedeck presentation.

8. ADJOURNMENT

Unanimous consent for adjournment approved.

Additional attendees:

CICC IFC/IBC JOINT COMMITTEE SIGN-IN SHEET		
Topic: Proposals	Meeting Date: 4 April 2019 0800	
Name	Company	E-Mail
Dave Kinn	URBANDALE	dkinn@URBANDALE.ORG
Scott Hayden	Ankeny	shayden@ankeny.iowa.gov
Tony Stearnes	Rockwell	tony.s@rockwell.iowa.gov
Kathi Rush	Waukegan	Krush@waukegan.org
Clayton Garcia	Clive FD	cgarcia@cityofclive.com
Ryan Mayer	Clive	Rmayer@cityofclive.com
Jeremy Eckhoff	Des Moines	jeckhoff@dm.gov.org
Brian Bishop	Des Moines	bbishop@dm.gov.org